

**Holmes & Holmes
Architects**
257 NORTH CONCEPTION STREET
P.O. BOX 864
MOBILE, ALABAMA 36601
PH. (251) 432-8871 – FAX (251) 433-7096

NICHOLAS H. HOLMES JR., FAIA
NICHOLAS H. HOLMES III, AIA
K.I.M. KEARLEY, R.A., AL
LEIGH SAYE RICE, R.A., AL
GEORGE HEUBACH

NICHOLAS H. HOLMES, AIA
(1878-1957)

**ADDENDUM No. 3
To the
Plans and Specifications
For
A New Facility for the
Fairhope Yacht Club**

**101 Volanta Avenue
Fairhope, Alabama**

April 23, 2007

**Item #1 – Sheet S-2
Item #2 – Clarification
Item #3 – Painting Schedule**

ITEM # 1 – Sheet S-2

Note #1 should read as follows:

- 1.) Metal deck 0.6C22GA (Galvanized) Type G90 Coating

See specifications 5C-1 Floor Decks, which is correct.

ITEM # 2 – Clarification

The concrete block walls at ground level men's and women's changing rooms (001, 002) do not receive waterproofing. They are to be painted as scheduled below in Item #3 this addition.

ITEM # 3 – Painting Schedule

- 1.) All new CMU walls shall be painted as the concrete/stucco specifications on Sheet 9C-4 of the specifications.
- 2.) Exterior wood, on Sheet 9C-4 of the specifications, shall receive a third coat the same as the second.